

# CERTIFICATE OF COMPLIANCE



## Snowsound U.S.A.

### BAFFLE

70296-420

Certificate Number

08/04/2015 - 07/20/2024

Certificate Period

Certified

Status

UL 2818 - 2013 Gold Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

Decorative Display determined compliant in accordance with California Department of Public Health (CDPH) Standard Method V1.2-2017 using an Office Environment with an air change of  $0.68 \text{ hr}^{-1}$  and a loading of  $3.00 \text{ m}^2$ .

Product tested in accordance with UL 2821 test method to show compliance to emission limits on UL 2818. Section 7.1 and 7.2.



UL investigated representative samples of the identified Product(s) to the identified Standard(s) or other requirements in accordance with the agreements and any applicable program service terms in place between UL and the Certificate Holder (collectively "Agreement"). The Certificate Holder is authorized to use the UL Mark for the identified Product(s) manufactured at the production site(s) covered by the UL Test Report, in accordance with the terms of the Agreement. This Certificate is valid for the identified dates unless there is non-compliance with the Agreement.

## GREENGUARD Gold Certification Criteria for Furniture and Mattresses

| Criteria                                | CAS Number | Maximum Allowable Predicted Concentration | Units             |
|---|------------|---|-------------------|
| TVOC <sup>(A)</sup>                     | -          | 0.22                                      | mg/m <sup>3</sup> |
| Formaldehyde                            | 50-00-0    | 9 (7.3 ppb)                               | μg/m <sup>3</sup> |
| Total Aldehydes <sup>(B)</sup>          | -          | 0.043                                     | ppm               |
| 4-Phenylcyclohexene                     | 4994-16-5  | 6.5                                       | μg/m <sup>3</sup> |
| 1-Methyl-2-pyrrolidinone <sup>(C)</sup> | 872-50-4   | 160                                       | μg/m <sup>3</sup> |
| Individual VOCs <sup>(D)</sup>          | -          | 1/2 CREL<br>or<br>1/100th TLV             | -                 |

- (A) Defined to be the total response of measured VOCs falling within the C<sub>6</sub> – C<sub>16</sub> range, with responses calibrated to a toluene surrogate.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Based on the CA Prop 65 Maximum Allowable Dose Level for inhalation of 3,200 μg/day and an inhalation rate of 20 m<sup>3</sup>/day.
- (D) Allowable levels for chemicals not listed are derived from the lower of 1/2 the California Office of Environmental Health Hazard Assessment (OEHHA) Chronic Reference Exposure Level (CREL) as required per the CDPH/EHLB/Standard Method v1.2 and BIFMA level credit 7.6.2 and 1/100th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).

